


# Index



# Index

	Clause	Section Number and Page		Clause	Section Number and Page
AA air gap			Approval of method of installation by the undertaker		
Description of backflow prevention device	S15.2	6.10	Water Byelaws 2000, Scotland	Byelaw 12	15
AB air gap			Water Supply (Water Fittings) Regulations	Reg.12(3)	7
Description of backflow prevention device	S15.2	6.10	Approval of specification by the Regulator		
Abbreviations		vi	Water Supply (Water Fittings) Regulations	Reg. 12 (1) – (2)	7
AC air gap			Approved materials		
Description of backflow prevention device	S15.2	6.10	Circumstances where not required	G2.6	2.14
Access cover			Compliance with Regulators' Specification		16
Requirements for 1,000 litre plus cistern	G16.13	7.11	Arrestors		
Access to float operated valves			For prevention of water hammer	G5.4	3.14
Cold water storage cistern	G16.14	7.14	Ascending spray bidets		
Access to operational valves	G10.2	4.12	Backflow protection for	G15.9	6.28
Accessibility			AUK1 air gap		
Cold water storage cistern	G16.14	7.14	With interposed cistern, description of	S15.2	6.10
Stopvalve, servicing and drain taps	G10.1	4.12	AUK2 domestic tap gap		
To operate stopvalves etc.	G10.2	4.12	Description of backflow prevention device	S15.2	6.10
Accessibility of water fittings	G7.1	3.17	AUK3 higher risk tap gap		
AD air gap			Definition of backflow prevention device	S15.2	6.11
Description of backflow prevention device	S15.2	6.10	BA reduced pressure zone valve		
Adhesive joints			Description of backflow prevention device	S15.3	6.11
Prohibition below ground	G7.10	3.24	Relief outlet requirements	G15.7f	6.27
AF air gap			Backflow w		
Description of backflow prevention device	S15.2	6.10	Definition of	R15.4	6.26
AG air gap			Backflow allowed in hot water supply pipes	G15.1	6.24
Description of backflow prevention device	S15.2	6.10	Backflow device		
Ageing			Accessibility	G15.7a	6.27
Effect of, in selection of fittings	G2.5	2.13	Burial in the ground	G15.7c	6.27
Agricultural water troughs			Inspection of	G15.7a	6.27
Water troughs to comply with BS 3445	G30.4	12.6	Line strainers servicing valve, need for	G15.7e	6.27
Air gap			Line strainers, requirement for	G15.7e	6.27
AA, with unrestricted discharge	S15.2	6.10	Location outside premises	G15.7b	6.27
AB, weir overflow	S15.2	6.10	Maintenance	G15.7a	6.27
AC, vented submerged inlet	S15.2	6.10	Operation	G15.7a	6.27
AD, with injector	S15.2	6.10	Renewal of	G15.7a	6.27
AF, circular overflow	S15.2	6.10	RPZ relief outlet requirements	G15.7f	6.27
AG, with minimum circular overflow	S15.2	6.10	Suitability for backpressure or backsiphonage	G15.7	6.27
AUK1, with interposed cistern	S15.2	6.10	Suitability for risk	G15.3	6.25
Definition	S15.1	6.10	Vented & verifiable, not in ground	G15.7d	6.27
Air pressure vessel fire sprinklers			Backflow prevention		
Fluid category	G15.28	6.49	Accessibility of backflow prevention devices and arrangements	G15.7	6.27
Alarms			Air gaps at taps or other terminal fittings	R15.13.1	6.36
Audible warning device for storage cisterns	G16.5	7.6	Animal drinking bowls	G30.3	12.5
Allowed backflow	G15.1	6.24	Animal drinking bowls, from supply pipe	G30.3c	12.5
Animal drinking troughs			Animal drinking troughs with AA air gap	G30.3b	12.5
Backflow prevention	R30.3	12.5	Animal drinking troughs, interlinked	G30.3a	12.5
General	R30.1	12.4	Backflow device adequate for purpose	Schedule 2, 15(5)	6.8
Location of servicing valve	R30.2	12.4	Backflow prevention arrangements and devices	G15.4	6.25
Specification to BS 3445	G30.4	12.6	Bidets supplied over the rim	R15.11	6.32
Anti vacuum valve DA			Bidets with flexible hoses, installation of	G15.10	6.29
Description of backflow prevention device	S15.3	6.11	Bidets with hoses and/or inlets below spillover level	R15.9	6.28
Anti vacuum valve with single check valve DUK1				R15.10.1/3	6.30
Description of backflow prevention device	S15.3	6.11	Class of backflow device	Schedule 2, 15(3)	6.8
Application of Byelaws			Combination tap assemblies	R15.13.2	6.37
Water Byelaws 2000, Scotland		11			
Application of Regulations					
Water Supply (Water Fittings) Regulations		4			

	Clause	Section Number and Page		Clause	Section Number and Page
Backflow prevention (continued)					
Commercial, industrial and laboratory applications	R15.30	6.50		G15.13	6.36
Devices for application of fertilisers or domestic detergents	R15.22	6.43		G15.14	6.38
Diagrams of backflow prevention arrangements	6.13 –	6.21			
Direction of flow	R15.3	6.25		G15.13	6.36
Drinking water fountains	G15.15	6.41		R16.9	7.9
Examples of fluid categories –	Tables	6.2/4		4(b), Table	5
	R15.2	6.25		G15.14	6.38
Exceptions to backflow requirements	R15.1	6.24		G28.1	10.6
	Schedule 2			G15.9	6.28
	15(2)	6.8			
Existing hose taps, house garden use	R15.21	6.43		G15.11	6.32
Fire protection systems	R15.27	6.48			
General interpretations of backflow prevention devices	S15.3	6.11		G15.9	6.28
General interpretations of terms relating to backflow prevention	S15.1	6.10		G15.11	6.32
Hose pipes for house gardens and other applications	R15.17	6.41			
Hose taps adjacent to WCs	R15.12.2	6.35		G15.13	6.36
Hose taps, house garden use	R15.20	6.42		G15.9	6.28
Industrial and commercial	G15.18	6.41		G15.11	6.32
Interpretations of backflow prevention arrangements	S15.2	6.10			
Mini irrigation systems in house gardens	R15.23	6.44		G15.13	6.36
Miscellaneous commercial and industrial applications	R15.30	6.50		G15.9	6.28
Non-mechanical backflow prevention arrangements	R15.5	6.26		G15.10	6.29
Ponds, pools and fountains	G31.2	12.6			
Porous hose irrigation systems	R15.19	6.42			
Precautions where pumped appliances are installed	R15.8	6.28			
Pressure flushing valves for WCs and urinals	R15.12.1	6.33			
Protection appropriate to highest risk downstream	Schedule 2				
	15 (3)	6.8			
Requirement to notify installation to water supplier	Reg. 5	5			
Secondary backflow protection – Common supply pipes	R15.24.3	6.46			
Secondary backflow protection – Distributing pipes	R15.24.4	6.46			
Secondary backflow protection – General	R15.24.2	6.46			
Secondary backflow protection – Requirements for	R15.24.1	6.46			
Secondary backflow protection in two storey premises	R15.6	6.27			
Separately occupied properties	Schedule 2				
	15.4(a)	6.8			
Separation of domestic and fire protection supplies	R15.29	6.49			
Submerged outlets to washbasins or baths	R15.14	6.38			
Washing machines, washer – driers and dishwashers	R15.16	6.41			
Whole site and zone protection	R15.26	6.47			
Backpressure					
Description of	R15.4a	6.26			
Backsiphonage					
Description of	R15.4b	6.26			
Bath inlet above spillover					
Backflow protection	G15.13	6.36			
Bath inlet below spillover					
Backflow protection	G15.14	6.38			
Baths					
Bath taps	G15.13	6.36			
Combined overflow/warning pipe discharge	R16.9	7.9			
Notification of large volume	4(b), Table	5			
Submerged inlets	G15.14	6.38			
Waste outlets	G28.1	10.6			
Ascending spray	G15.9	6.28			
Bidets					
Backflow protection – over the rim supply	G15.11	6.32			
Backflow protection - submerged inlet or flexible hose	G15.9	6.28			
Over the rim type, backflow prevention for	G15.11	6.32			
Bidets inlet above spillover					
Backflow protection	G15.13	6.36			
Bidets inlet below spillover					
Backflow protection	G15.9	6.28			
Bidets with ascending spray					
Backflow prevention, alternative methods	G15.10	6.29			
Boats					
Backflow prevention	R15.30	6.51			
Booster pumps					
Need for written approval for installation of	G6.1	3.15			
British Standards					
Reference to, in selection of fittings	G2.4	2.13			
Building Regulation G3					
Installation of unvented hot water storage	G19.1	8.10			
Buried cisterns					
Design and installation	R16.13.1	7.12			
CA non-verifiable disconnecter					
Description of backflow prevention device	S15.3	6.11			
Capillary fittings					
Use of	R2.1.4	2.8			
Cathodic protection					
Protection of copper cylinders by	G3.4	3.5			
Access cover, cistern over 1,000 litres	G16.13	7.11			
Cisterns					
Accessibility	G16.14	7.14			
Bottom outlets from cisterns	G16.6	7.7			
Coatings	G16.13	7.11			
Common warning or overflow pipes from two or more cisterns	R16.15	7.15			
Common warning pipes, need for	G16.12	7.11			
Condensate on lid, contamination of	G16.13	7.11			
Discharge points of warning and overflow pipes	R16.9	7.9			
Domestic, protection against freezing	G4.2/3	3.6			
Exclusion of insects	G16.13	7.11			
Filling rate, per slab width, urinals	G25.12b	9.13			
Filling rates, automatic urinal	G25.12a	9.13			
Fixing of float control devices	R16.5	7.6			
Fixing of inlet valves	G16.5	7.6			
Inlets to cisterns	R16.4	7.6			
Lid specification	G16.13	7.11			
Linking together	G16.15	7.15			
Maintaining water temperature in storage combination units	R16.13.4	7.13			

# Index

	Clause	Section Number and Page		Clause	Section Number and Page
Cisterns (continued)			Conspicuous discharge		
Minimum headroom	G16.14	7.14	Requirement for, from cistern warning pipe	G16.12	7.11
Minimum size of warning pipe	R16.10	7.10	Consumption of water		
Outlets from cisterns serving primary circuits	R16.7	7.7	Dish-washer, domestic	G29.3	11.4
Provision of adequate support to cisterns	R16.14	7.15	Washer-drier, domestic	G29.2	11.4
Reduced requirements for cisterns serving primary circuits	R16.13.5	7.13	Washing machine, domestic	G29.1	11.4
Reduction of microbiological growth in cisterns	R16.13.3	7.13	Contaminated ground		
Supplying hot water systems	G20.4	8.15	Installation of pipes or fittings in	G4.16	3.12
Support of	G16.14	7.14	Contamination of materials		
Vermin screens to warning and overflow pipes	R16.11	7.10	Materials and substances in contact with water	G2.1	2.4
Warning & overflow provisions	G16.13	7.11	Contamination of water		
Warning and overflow pipes	G16.8	7.8	Ban on substances which may cause –	G2.1	2.4
Warning level relative to overflow	G16.5	7.6	By permeation of fluids	G4.14/15	3.11
Water tight construction, requirements for	G16.13	7.11	Location of cistern in contaminated locations	R8.6	4.10
Citation, commencement and interpretation			Restriction on fittings in contaminated environment	R8.5	4.9
Water Byelaws 2000, Scotland		11	Contractor's certificate		
Water Supply (Water Fittings) Regulations		3	Water Byelaws 2000, Scotland		14
Coal tar products			Water Supply (Water Fittings) Regulations		6
Prohibition of the use of	G2.1	2.4	Contravention of byelaws and defences		
Coatings			Water Byelaws 2000, Scotland		14
Cistern, cold water	G16.13	7.11	Contravention of regulations and defences		
Cold water temperatures			Water Supply (Water Fittings) Regulations		6
Maximum distribution temperature	G9.1	4.10	Control of flushing		
Colour coding of pipes			Urinals, automatic or manual	G25.10	9.10
To prevent cross connection	G14.1	5.4	Control of water entering a building	G10.5	4.14
Combi boiler flow rates	G8.4	4.9	Control of water to premises	G10.3	4.12
Combination hot water storage units			Convenient drinking tap		
Temperature of distributed water	G18.2/4	8.9	Requirement for	G26.1	10.4
Combination taps			Copper cylinders		
Appropriate for flow and pressure	G2.9	2.15	Cathodic protection for	G3.4	3.5
Backflow prevention	R15.13.2	6.37	Effect of local water on	G3.4	3.5
Standards for high and low pressure	G2.10	2.15	Thickness of	G3.4	3.5
Combined temperature and pressure relief valves			Covering operational valves	G10.2	4.12
Need for HW Storage above 15lts capacity	G17.1b	8.4	Critical water level		
Requirements for operation	G22.1	8.21	Definition	R15.1	6.10
Requirements for the provision of	G23.1	8.22	Cross connections		
Common connection			To unwholesome water, prevention of	G14.2	5.5
Domestic & fire supplies, backflow protection	G15.29	6.49	DA anti-vacuum valve		
Common supply pipes			Description of backflow prevention device	S15.3	6.11
Secondary backflow protection	G15.24	6.45	Damage to water fittings		
Common warning pipes			Protection for the prevention of	G4.17	3.12
Discharge from overflow in one cistern to another	G16.9/12	7.9	DB pipe interrupter		
Compatibility of different materials			Description of backflow prevention device	S15.3	6.11
Selection of fittings	G2.5	2.13	DC pipe interrupter		
Concealed fittings			Description of backflow prevention device	S15.3	6.11
Accessibility	G7.1	3.17	Dead legs		
Gunmetal	G7.4	3.21	Removal of	G11.7	4.16
In solid floors	G7.3	3.21	Default pressures		
Requirement for dezincification resistance	G7.5	3.21	Fittings to withstand	G4.1	3.6
Condensate			Depth of cover		
Cistern lid, contamination due to	G16.13	7.11	For underground pipes	G7.7	3.22
Connection for filling			Design of water systems		
Closed circuits for heating systems	G24.1/2	8.24	Flow rates and pipesizing	R8.3	4.8
Connection for warning pipe			Flow rates with instantaneous boilers	R8.4	4.9
Requirement for, in WC cisterns	G25.6	9.6	General considerations	R8.1	4.4
			Types of distribution systems	R8.2	4.7

	Clause	Section Number and Page		Clause	Section Number and Page
Detergent dispensing by garden hose			Drain taps		
Backflow protection	G15.22	6.43	Buried	G11.6	4.15
Deterioration of materials			Frost-free location	G11.5	4.15
Galvanic action	R3.2	3.4	Labelling	G4.10	3.8
Dezincification			Operating requirements of	G2.7	2.14
Concealed fittings, safety devices and backflow prevention devices	R7.5	3.21	Provision of	G11.4	4.15
Marking of fittings	G7.6	3.21	Spherical type	G11.5	4.15
Resistant fittings below ground	G7.9	3.24	Standards for	G11.5	4.15
Thickness of protection	G7.6	3.21	Submerged	G11.6	4.15
Use of DZR fittings	G7.4	3.21	Thermostatically controlled for prevention of freezing	G4.5	3.7
Discharge from warning pipes			Types of drain taps	G11.5	4.15
Need for conspicuous discharge	G16.12	7.11	Draining supply and distribution pipes	G11.4	4.15
Requirements for	G16.8	7.8	Drinking water		
Discharge pipe			Alternative sources of drinking water supplies	R27.2	10.4
Expansion & temperature relief valves	G19.1/3	8.10	Drinking water points in houses	R26.2	10.4
Disconnection of disused fittings and branch pipes			Labelling of drinking water taps	R27.4	10.5
Redundant fittings and dead legs	R11.7	4.16	Provision of wholesome supply	R27.1	10.4
Dishwashers			Standards for installation of supply to pigs	G30.5	12.6
Domestic use, backflow protection	G15.16	6.41	Water softened on the premises	R27.3	10.5
Non-domestic use, backflow protection	G15.16	6.41	Drinking water fountain		
Disinfection			Backflow protection	G15.15	6.41
Disposal of disinfection fluid	R13.3.5	4.21	Outlet plug not required	G28.1e	10.6
Following suspected contamination	G13.2d	4.19	Drinking water tap		
For systems not regularly used	G13.2e	4.19	Requirement for tap off supply pipe	R26.1	10.4
Introduction of disinfection fluid to the water system	R13.3.2	4.20	Dual and single flush		
Major extensions and alternations	G13.2b	4.19	Replacement of existing WCs	G25.15	9.15
New installations	G13.2a	4.19	Dual flush operation		
Procedure	R13.3.1	4.20	Instructions for use of	G25.5	9.6
Underground pipework	G13.2c	4.19	Dual flush WCs		
Using chlorine	R13.3.3	4.20	Limit for lesser flush volume	G25.3	9.5
Using other than chlorine	R13.3.4	4.21	Ductile iron pipes		
Disputes			Specification and installation requirements	R2.1.3	2.5
Water Byelaws 2000, Scotland		15	Ducts		
Water Supply (Water Fittings) Regulations		8	Removal of pipes from	G7.3	3.21
Distinguishing types of pipes			Requirement for pipes in	G7.2	3.20
Colour coding of pipelines	R14.1	5.4	Sealing of	G7.2	3.20
Distributing pipes			DUK1 anti vacuum valve		
Definition	R1.1.3	1.6	Description of backflow prevention device	S15.3	6.11
Provision of drain taps for	G11.4	4.15	Durability		
Distribution systems			Effect of, in selection of fittings	G2.5	2.13
Types of	G8.2	4.5	EA verifiable single check valve		
Distribution temperature			Description of backflow prevention device	S15.3	6.11
Cold water, maximum recommended	R9.1	4.10	EB non-verifiable single check valve		
Diverter with automatic return			Description of backflow prevention device	S15.3	6.11
HC backflow prevention device, description of	S15.3	6.12	EC verifiable double check valve		
Domestic hose			Description of backflow prevention device	S15.3	6.11
Backflow protection	G15.20	6.42	ED non-verifiable double check valve		
Domestic hose, existing			Description of backflow prevention device	S15.3	6.12
Backflow protection	G15.21	6.43	Effect of water on copper cylinders	G3.4	3.5
Double check valves			Embedding of pipes		
Location of, on domestic hoses	G15.20	6.42	Accessibility	G7.1	3.17
Downstream backflow risk			Energy conservation		
Related to fluid categories	G15.3	6.25	Maximum hot water pipe length	G18.7	8.10
Drain down			Enforcement		
To prevent freezing	G4.3	3.6	Water Supply (Water Fittings) Regulations		7
			Exceptional freezing conditions		
			Precautions against,	G4.3	3.6

# Index

	Clause	Section Number and Page		Clause	Section Number and Page
Exclusion of insects			Freezing		
Cold water storage cistern	G16.13	7.11	Extreme conditions	G4.3	3.6
Existing flushing cistern			G4.11b	G4.11b	3.9
Replacement by cistern of similar volume	G25.15	9.15	Factors in the prevention of	G4.4	3.7
Expansion cistern			In unoccupied properties, prevention of	G4.3	3.6
Capacity and water level	G21.1	8.21	Normal conditions, protection for	G4.11 a	3.8
Expansion relief valves			Protection of fittings outside		
Discharge pipe specification	G19.4	8.13	thermal envelope	G4.2	3.6
Expansion system			Shut off & drain down	G4.3	3.6
Integral expansion system	G17.1d	8.4	Frost protection		
Expansion system malfunction			Distinction between normal and		
Safe discharge expansion relief valve	G17.2	8.7	extreme conditions	G4.11	3.8
Expansion valves			Effectiveness of insulation	G4.4/.8	3.7
Expansion valve specification	G22.2	8.22	Exceptionally cold circumstances	G4.5	3.7
Requirement for, if HW storage over 15 litres	G17.2	8.7	For expansion & temperature relief pipes	G19.2	8.11
Requirements for –	G22.1	8.21	General provisions	G4.1/.13	3.6
Specification to BS6283(1)	G22.2	8.22	Insulation materials	G4.6/.7	3.8
Expansion water			Insulation of cisterns	G4.13	3.10
Accepted into cold water storage cistern	G20.4	8.15	Insulation to hot water pipes	G4.9	3.8
Expansion vessel flow through type	G17.3	8.8	Location of pipes	R4.3	3.6
Maintaining cold water temperature	G20.5	8.18	Thermal envelope	R4.2	3.6
Primary feed and expansion cisterns	G21.1	8.21	Trace heating	R4.12	3.10
Returned to the supply pipe	G17.1d	8.4	Frost stats		
Water level in feed and expansion cisterns	G21.1	8.21	For prevention of freezing	G4.5	3.7
External corrosion			Galvanic action		
Effect of, in selection of fittings	G2.5	2.13	Effect of mixed materials	G3.2	3.4
External temperatures			Protection against	G2.11	2.15
Effect of, in selection of fittings	G2.5	2.13	With lead and other materials	G2.11	2.15
Fatigue of materials			Garden hoses		
Effect of, in selection of fittings	G2.5	2.13	Backflow protection – domestic	G15.20	6.42
Fertiliser dispensing by garden hose			Gas permeation		
Backflow protection	G15.22	6.43	Plastics and permeable materials	R4.16	3.12
Fire sprinklers and hose reels			Gate valves		
Backflow protection	G15.27	6.48	Requirements of	G2.8	2.14
Fittings approval			Grey water		
Use of approved test house	G2.3	2.13	Colour-coded pipes to distinguish	G14.1	5.4
Fixing of water fittings			Guidance		
Recommended spacing of pipe supports	G4.17/.18	3.12	General, Regulations/Byelaws 2000		16
Float operated valves			Gunmetal fittings		
Animal drinking troughs or bowls	G30.1	12.4	Requirement for concealed fittings	G7.3	3.21
Flow control for cisterns using	G16.1	7.4	HA hose union backflow preventer		
For use with hot water	G16.3	7.6	Description of backflow prevention device	S15.3	6.12
Requirements for	R16.2	7.4	HC diverter with automatic return		
Flow rate			Description of backflow prevention device	S15.3	6.12
Combination boilers, hot water temperatures	G18.4	8.9	Health care premises		
Flow reduction			Temperature of hot water pipes and outlets	G18.6	8.10
Insect screen on overflow causing	G16.11	7.10	Hose pipe for house garden		
Fluid categories			Hand held hoses with self closing mechanism	G15.17	6.41
Backflow device related to downstream risk	G15.3	6.25	Hose pipe materials		
Definitions and examples of	Section 6.1	6.2	Use with washing machines etc.	G2.6	2.14
Flushing of water services			Hose union backflow preventer		
Recommendation to follow BS6700	R13.1	4.19	HA backflow prevention device	S15.3	6.12
Flushing urinals			Hose union tap incorporating double check		
Flushing rate, complies with BS 1876	G25.12	9.13	HUK1 backflow prevention device	S15.3	6.12
Flushing valve, manual			Hot water float valves		
For urinal or WC flushing	G15.12	6.33	Requirements for	G16.3	7.6
Foreword		vii	Hot water pipes		
Fountain, drinking water			Maximum un-insulated lengths	G18.7	8.10
Backflow protection	G15.15	6.41	Hot water systems		
			Closed primary circuits – fluid category	R24.2	8.24
			Closed primary circuits – general	R24.1	8.24

	Clause	Section Number and Page		Clause	Section Number and Page
Hot Water Systems (continued)			Internal temperatures		
Discharge pipes from expansion valves	R19.4	8.13	Effect of, in selection of fittings	G2.5	2.13
Discharge pipes from safety devices	R19.1	8.10	Interpretations		
Expansion and safety devices	R22.1	8.21	Backflow prevention arrangements and devices	R1.1.2	1.4
Expansion valves – Requirements	R22.2	8.22	Backflow prevention arrangements	Table S15.2	6.10
Expansion vessels – Use of	R17.3	8.8	Backflow prevention devices	Table S15.3	6.11
Expansion water, effect on stored water temperature	R20.5	8.18	Chemical water conditioner	R1.1.3	1.7
Hot water distribution temperature	R18.2	8.9	Cisterns	R1.1.3	1.6
Independent water heaters	R17.1.1c	8.6	Communication pipes	R1.1.3	1.6
Indirectly heated HWS using high temperature primary heater	R20.7	8.20	Contamination of water supplied by an undertaker	R1.1.2	1.4
Maximum lengths of un-insulated pipe	R18.7	8.10	Critical water level	S15.1	6.10
Methods of accommodating expansion water	R17.1.3	8.6	Distributing pipe	R1.1.3	1.6
Minimum air gap at termination of vent pipe	R20.3	8.14	Erroneous measurement	R1.1.2	1.4
Non-mechanical safety devices	R23.2	8.23	General interpretations relating to backflow requirements	S15.1	6.10
Purpose of expansion valve	R17.2	8.7	Misuse	R1.1.2	1.4
Size of primary feed and expansion cisterns	R21.1	8.21	Physical water conditioner	R1.1.3	1.7
Temperature and combined temperature and pressure relief valves	R23.1	8.22	Service pipe	R1.1.3	1.5
Temperature of hot water at terminal fittings and on pipe surfaces	R18.4	8.9	Spillover level	S15.1	6.10
Temperature of water within a hot water storage system	R18.1	8.8	Supply pipe	R1.1.3	1.5
Thermostatic valves for safe use of	R18.5	8.9	Undue consumption	R1.1.2	1.4
Unvented hot water system with vented primary circuit	R17.1.2	8.6	Waste	R1.1.2	1.4
Unvented hot water systems	R17.1.1	8.5	Water fittings	R1.1.3	1.5
Vent pipe above warning pipe in cistern	R20.1	8.13	Water softener	R1.1.3	1.7
Vented hot water systems requiring dedicated cold water cisterns	R20.6	8.18	Wholesome water	R1.1.3	1.5
HUK1 hose union tap			Irrigation systems		
Description of backflow prevention device	S15.3	6.12	Backflow protection	G15.19	6.42
Impervious lining			Joints on pipes and fittings		
Fountains, ponds and pools	G31.1	12.6	Adhesives and underground pipes	R7.10	3.24
Independent cold water distributing pipe			Joining of different types of materials	R2.11	2.15
Ascending spray bidets installation	G15.10	6.29	Jointing compounds	R2.15	2.16
Inlet servicing valve			Pipes, pipe fittings and joints	R2.1	2.4
Animal drinking bowls	G30.2	12.4	PTFE tape	R2.16	2.16
Inlet to cistern, requirement for	G16.4	7.6	Silver solder or brazing material	R2.13	2.16
Insecticide dispensing by garden hose			Soft solders	R2.12	2.16
Backflow protection	G15.22	6.43	Soft solders and stainless steel pipes	R2.14	2.16
Inspections, measurements and tests			Joists		
Water Byelaws 2000, Scotland		14	Notching for pipe installation	G7.1	3.17
Water Supply (Water Fittings) Regulations		7	Key to symbols		vi
Instantaneous water heater flow rates	G8.4	4.9	LA pressurised air inlet valve		
Instructions			Description of backflow prevention device	S15.3	6.12
Display of, for dual flush WC operation	G25.5	9.6	Labelling		
Insulation			Servicing valves	G4.10	3.8
Conditions affecting the efficiency of	G4.4	3.7	Stopvalves	G4.10	3.8
Hot water fittings outside thermal envelope	G4.9	3.8	Taps in non domestic premises	G27.4	10.5
Roof space, protection of fittings by	G4.13	3.10	LB pressurised air inlet valve, with check valve		
Storage cisterns	G4.13	3.10	Description of backflow prevention device	S15.3	6.12
Insulation materials			Lead, lead alloys or coal tar products		
Close cell type	G4.6	3.8	Prohibition of the use of	G2.1	2.4
Essential installation requirements	G4.8	3.8	Lengths of hot distribution pipes		
Protection against damage	G4.8	3.8	Maximum un-insulated	G18.7	8.10
Protection against moisture	G4.8	3.8	Lid specification		
Thermal conductivity	G4.7	3.8	Cold water storage cistern	G16.13	7.11
Internal corrosion			Linking together cisterns		
Effect of, in selection of fittings	G2.5	2.13	Preventing short circuiting	G16.15	7.15

# Index

	Clause	Section Number and Page		Clause	Section Number and Page
Location of operational fittings	G10.2	4.12	Stopvalves – provision to premises	R10.3	4.12
Location of servicing valves	G11.2	4.14	Types of servicing valves	R11.3	4.14
Location of stopvalves	G10.5	4.14	Water supplies in common to two or more premises	R10.4	4.14
Location of water fittings			Outlets, cisterns		
Concealed fittings	R7.3	3.21	Requirement for servicing valve	G16.7	7.7
Pipes entering premises below ground level	R7.2	3.20	Outlets, waste		
Requirements for	R7.1	3.17	Plugs, requirements and exemptions	R28.1	10.6
Maintenance			Outside fittings		
Stopvalves, servicing valves and drain taps, access for	G10.1	4.12	Protection against freezing	G4.2	3.6
Use of servicing valves to facilitate	G11.1	4.14	Over the rim bidet		
Maximum flush volume			Backflow prevention for	G15.11	6.32
WC, single and dual flush	G25.3	9.5	Overflow and warning pipes		
Maximum operating pressure	G5.1	3.14	For water storage	R16.8	7.8
Mini-irrigation systems			For WC	R25.6/8	9.6
Backflow protection	G15.23	6.44	Overflow inlet & outlet	G16.8	7.8
Minimum depth			Overflow pipes		
For underground pipes	G7.7	3.22	Capacity reduction due to screen	G16.11	7.10
Minimum headroom			Capacity related to inlet valve failure	G16.10	7.10
Cold water storage cistern	G16.14	7.14	Discharge arrangement, linked cisterns	G16.9/12	7.9
Mixing taps			Flexible hose attached to	G16.8	7.8
Backflow protection	R15.13.2	6.37	Required fall in installation	G16.8	7.8
Modification Water Industry Act Section 73	Reg. 8,	6	Requirement for	G16.10	7.10
Movement below ground			Requirement for, with 'no less effective' warning device	G16.8	7.8
Allowance for	G7.9	3.24	Permanently vented distribution pipes		
Movement of fittings			As backflow prevention devices	G15.6	6.27
Allowance for thermal or other cause	G4.18	3.12	Permeable hoses		
Night pressures	G5.2	3.14	For irrigation, backflow protection	G15.19	6.42
Non-mechanical safety device			Permeable materials		
Fusible plug thermal relief valves	G23.2	8.23	Location to avoid contamination	G4.14	3.11
Non-mechanical backflow devices			Petrol or oil contamination		
Preference for protection by	G15.5	6.26	In contact with plastic pipes	G4.16	3.12
Non-metallic materials			Pipe interrupter, moving element		
Compliance with BS6920	G2.2	2.13	DB device for backflow prevention	S15.3	6.11
Non-verifiable disconnecter			Pipe interrupter, permanent atmospheric		
CA device for backflow protection	S15.3	6.11	DC device for backflow prevention	S15.3	6.11
Non-verifiable double check valve			Pipe location		
ED device, for backflow protection	S15.3	6.12	To avoid contaminating fluids	G4.15	3.11
Non-verifiable single check valve			Pipe support	G4.18	3.12
EB device for backflow protection	S15.3	6.11	Pipes		
Notching joists			Entering premises underground	G7.2	3.20
For pipe installation	G7.1	3.17	In cavity walls or through joists	G7.1	3.17
Notification			Pipes underground		
Booster pumps	G6.1	3.15	Minimum depth	G7.7	3.22
Byelaw 5, Scotland		13	Pipes, mixed metals		
General commentary		16	Effect on corrosion	G3.2	3.4
Regulation 5, England and Wales		5	Pipes, pipe fittings and joints		
Operating pressure			Copper tubes	R2.1.4	2.8
Maximum design pressure	G5.1	3.14	Ductile iron pipes	R2.1.3	2.5
Operational fittings			Iron pipes	R2.1.3	2.5
Accessibility	R10.1	4.12	Lead pipes prohibited	R3.2	3.4
Concealed or decorative material covering	R10.2	4.12	Plastics pipes for hot and cold water use	R2.1.7	2.12
Examples	R10.1	4.12	Polyethylene pipes	R2.1.6	2.11
Location of servicing valves	R11.2	4.14	Stainless steel pipes	R2.1.8	2.12
Location of stopvalves in buildings	R10.5	4.14	Steel pipes	R2.1.2	2.4
Provision of draining taps	R11.4	4.15	Unplasticised pvc pipes	R2.1.5	2.10
Stopvalves – controlling more than single premises	R10.4	4.14	Pipesizing		
			Design flow rates and pipesizing	R8.3	4.8



	Clause	Section Number and Page		Clause	Section Number and Page
Plastic materials			Effect on system operating pressure	G5.2	3.14
Permeation of	G4.14	3.11	Limitation on discharge of pumped showers	R6.2	3.16
Plastic pipes			Location affecting backflow risks	G15.8	6.28
In contact with oil, petrol etc.	G4.16	3.12	Need for written approval for installation of	G6.1	3.15
Plastic pipes and fittings			Rain water		
Compliance with BS6920	G2.2	2.13	Colour-coded pipes to distinguish	G14.1	5.4
Plug cock			Recycled water		
Specification for	G2.8	2.14	Colour-coded pipes to distinguish	G14.1	5.4
Plugs – waste outlet			Reduced pressure zone valve (RPZ)		
Requirement for and exemptions	G28.1	10.6	BA device, description of, for backflow prevention	S15.3	6.11
Pneumatic pressure vessel fire sprinklers			Redundant fittings and dead legs		
Backflow protection	G15.28	6.49	Requirement for permanent removal	R11.7	4.16
Ponds, fountains and pools			Relaxation of requirements		
Backflow protection for water supply to	R31.2	12.6	Water Byelaws 2000, Scotland		15
Construction and lining	R31.1	12.6	Water Supply (Water Fittings) Regulations		7
Notification of construction of	Table Reg. 5	5	Removal of dead legs	G11.7	4.16
Porous hoses			Repair of fittings or appliances		
Irrigation, backflow protection of	G15.23	6.44	Exemption from Regulations/Byelaws		16
Position of servicing valve			Replacement of WCs	G25.15	9.15
Animal drinking bowls and troughs	G30.2	12.4	Requirement for backflow protection	Schedule 2 15(1)	6.8
Pressure flushing valves			Requirements for water fittings		
For WC flushing in non-domestic premises	G25.2	9.4	Water Byelaws 2000, Scotland		12
Pressure requirements			Water Supply (Water Fittings) Regulations		4
Design for operating pressure	G5.1/4	3.14	Restriction on installation etc. of water fittings		
Pressure testing	G12.1/3	4.17	Water Byelaws 2000, Scotland		12
Pressure surge			Water Supply (Water Fittings) Regulations		4
Attenuation devices	G5.4	3.14	Retrospective backflow protection		
Pressure testing			Garden hoses	G15.21	6.43
Metallic water systems	G12.2	4.17	Reverberation in pipes		
Plastic water systems	G12.3	4.18	Significance of surge pressure	R5.4	3.14
Pressurised air inlet valve			Revocation of byelaws		
LA device for backflow prevention	S15.3	6.12	Water Byelaws 2000, Scotland		15
Pressurised air inlet valve & check valve			Water Supply (Water Fittings) Regulations		8
LB device for backflow prevention	S15.3	6.12	Risk categories for backflow prevention devices		
Prevention of freezing			Mechanical devices	Table S15.3	6.12
Servicing valves and drain taps for isolation	G4.10	3.8	Non-mechanical devices	Table S15.2	6.11
Primary circuit vent			Routing of pipes		
Requirement for discharge size & point	G20.1	8.13	Maintenance of hot water temperatures	G18.3	8.9
Primary circuits			Safety devices		
Expansion of water in	R21.1	8.21	Control of water temperature by	G18.1	8.8
Primary feed cistern			Requirement to withstand operational temperatures	G3.3	3.5
Wholesome water not required for	G2.6	2.14	Unvented hot water systems	G17.1	8.4
Primary system cisterns outlets			Vented hot water storage, requirement for	G20.6	8.18
Requirement for servicing valve	G16.7	7.7	Safety valves		
Prismatic cylinders			Discharge arrangements for expansion & thermal relief	G19.1	8.10
Backflow prevention	G20.11	8.20	Requirements for discharge point	G19.4	8.13
Prohibited materials			Sanitary appliances		
Use of coal tar products, lead or lead alloys	G2.1	2.4	Automatic urinal cistern flushing rates	R25.12	9.13
Protection against damage			Dual flush operating instructions	R25.5	9.6
Water fittings	G4.17	3.12	Marking of maximum volume in WC flushing cistern	R25.4	9.5
Protection of insulation	G4.8	3.8	Maximum volume for flushing WC pans	R25.3	9.5
Protector rods			Pressure flushing valves for WC pans	R25.2	9.4
In copper cylinders	G3.4	3.5	Regulation of flushing periods for urinals	R25.11	9.11
Provision of servicing valves			Renewal of existing WC cisterns	R25.15	9.15
Requirements for	G11.1	4.14			
PTFE tape					
Specification for	G2.16	2.16			
Pumps					
Approval for installation of shower	R6.3	3.16			
Effect on distribution pipes	G15.8	6.28			

# Index

	Clause	Section Number and Page		Clause	Section Number and Page
Sanitary appliances (continued)			Shallow pipes		
Requirements for WC pans and WC flushing devices	R25.11	9.11	Need for written approval	G7.8	3.22
Urinal flushing devices	R25.9	9.8	Shower bath tray		
Urinals, maximum flush volume using pressure flushing valves	R25.13	9.14	Unplugged waste outlets	G28.1d	10.6
Visibility of discharge from warning pipe	R25.7	9.8	Shower heads, discharge above spillover		
Warning pipe discharging over WC pan or urinal	R25.8	9.8	Backflow protection	G15.13	6.36
Warning pipes from WC cisterns	R25.6	9.6	Showers – pumped		
WC flushing capacity and method to Jan 2001	R25.14	9.15	Need for written approval for installation of	G6.2	3.16
WC flushing – single or dual flush	R25.1	9.4	Showers – Regulators' specified		
Schedule 1 – Fluid Categories Regulations/Byelaws 2000		20	Need for written approval for installation of	G6.3	3.16
Schedule 2 – Requirements for water fittings Regulations/Byelaws 2000			Silver solder		
1.3, 2.3, 3.3, 4.3, 5.3, 6.8, 7.3, 8.3, 9.2, 10.3, 11.3, 12.3			Use for stainless steel capillary joints	G2.13	2.16
Scottish Water Byelaws			Simultaneous discharge rates		
Full text		11–15	Hot and cold water, combi systems	G8.4	4.9
General Guidance		16–17	Single check valve verifiable		
Summary		10	EA backflow prevention device, description	S15.2	6.11
Screwed joints			Single feed indirect cylinders		
Jointing compounds for	G2.15	2.16	Requirement to be vented	G20.11	8.20
Secondary use of permanently vented distribution pipes	G15.6	6.27	Single supply pipe		
Secondary backflow protection			For domestic and fire purposes	G15.29	6.49
Distributing pipes	R15.24.4	6.46	Siphonic flushing		
In two storey premises	R15.6	6.27	Volume of WC flush prior to Jan 2001	G25.14	9.15
Industrial and commercial applications	G15.18	6.41	Softened water		
Requirement for	R15.24.1	6.46	Requirement to be wholesome for drinking	G27.3	10.5
Supply pipes	R15.24.3	6.46	Soil watering systems		
Vented distribution pipes	G15.6	6.27	Backflow protection	G15.19	6.42
Whole site and zone protection	R15.24/26	6.45	Solder		
Secondary circulation systems			For stainless steel	G2.14	2.16
Thermal insulation of	G18.7	8.10	Lead-free for capillary joints of copper	G2.12	2.16
Secondary vent pipes			Solid floors		
Minimum internal diameter	G20.2	8.14	Pipes in	G7.1	3.17
Selection of fittings			Specification		
Factors having an effect on	G2.5	2.13	Expansion relief valves discharge pipe	G19.4	8.13
Fittings down stream of terminal fittings	G2.6	2.14	Regulators', for WC pans & flushing devices	G25.11	9.11
Self-closing mechanism			Specification for PT FE		
Domestic hoses	G15.17	6.41	Tape for thread sealing applications	G2.16	2.16
Service pipe			Spherical type servicing valves	G11.3	4.14
Definition	R1.1.3	1.5	Spillover level		
Servicing valves			Definition	S15.1	6.10
Animal drinking troughs or bowls	G30.2	12.4	Stagnant water		
For float valves, backflow prevention devices & appliances,	G11.1	4.14	Preventing, in cold water storage cisterns	G16.15	7.15
Labelling	G4.10	3.8	Stainless steel		
Location adjacent to appliance	R11.2	4.14	Solder for capillary jointing of	G2.14	2.16
Location of	G7.1	3.17	Standards		
	G11.2	4.14	Float operated valves	G16.2	7.4
On inlets to storage cisterns	G16.4	7.6	Stopvalves		
Operating requirement of	G2.7	2.14	Controlling more than single premises	G10.4	4.13
Outlets to cisterns	G16.6	7.7	Inside buildings	G10.4/5	4.13
Prohibition of loose washer plate	G2.7	2.14	Labelling	G4.10	3.8
Types of	G11.3	4.14	Location in buildings	R10.5	4.14
Use with line strainers	G15.7e	6.27	Location on common supply pipe	G10.4	4.13
			Occupiers' access to	G10.4	4.13
			On distribution pipes	G10.3	4.12
			On supply pipes	G10.3	4.12
			Operating requirements of	G2.7	2.14
			Outside buildings	G10.4	4.13
			Point of entry	G10.5	4.14
			Prohibition of loose washer plate	G2.7	2.14
			Requirement for control of water supply	G10.3	4.12
			Specification below ground	G2.8	2.14
			To premises	G10.3	4.12



















	Clause	Section Number and Page		Clause	Section Number and Page
Storage cisterns			Temporary connection		
Insulation of	G4.13	3.10	Fountains, ponds and pools	G31.2	12.6
Use for supply for domestic purposes	G16.13	7.11	Terminal fittings		
Storage vessel			Draw-off taps	R2.10	2.15
Hot water, single feed indirectly heated	R20.4.3	8.17	Exclusion from requirement for dezincification resistance	G7.5	3.21
Submerged drain taps			Suitability for pressure and flow requirements	R2.9	2.15
Prohibition of	G11.6	4.15	Test house		
Suitability of fittings			Use of approved, for materials and fittings	G2.3	2.13
Adequate for purpose	G3.1	3.4	Test pressures		
Factors to be considered	G2.5	2.13	Requirements for	G12.1	4.17
Need to withstand operational temperature	G3.3	3.5	Testing		
Summary			Pressure testing of rigid pipe systems	R12.2/3	4.17
Water Byelaws 2000 for Scotland		10	Pressure testing plastics pipes	R12.3	4.18
(Water Supply) Regulations 1999		2	Requirement for pressure testing	R12.1	4.17
Supply pipe			Thermal conductivity		
Definition	R1.1.3	1.5	Of insulation materials	G4.7	3.8
Provision of drain tap	G11.4	4.15	Thermal envelope		
Supply to animals			Protection of hot water fittings outside of,	G4.9	3.8
Flow control, drinking bowls	G30.1	12.4	Thermal insulation materials		
Support of cisterns			Standards for	G4.6	3.8
Requirement for	G16.14	7.14	Thermal movement in pipes		
Support of pipes			Allowance for, in installation	G4.18	3.12
Requirement for	G4.18	3.12	Thermal safety devices		
Surface temperatures			Requirements for	G20.6/7	8.18
Pipes in health care premises	G18.6	8.10	Thermostatic control		
Surge pressure			Automatic and manual re-setting	G20.6/7	8.18
Effect on test pressure requirements	G5.3	3.14	Control of temperature at hot outlets using	G18.5	8.9
Significance of	R5.4	3.14	Terminal fittings, hot water in public buildings	G18.5	8.9
Suspended floors			Time and temperature		
Pipes under	G7.1	3.17	Hot water temp / time specification	G18.4	8.9
Tap gap			Instantaneous water heaters hot water temperatures	G18.4	8.9
Definition	S15.1	6.10	Temperatures of hot water at terminal fittings	G18.4	8.9
Tap gap domestic AUK2			Trace heating		
Description for	S15.2	6.10	Self regulating for frost protection	G4.12	3.10
Tap gap high risk			Trains		
AUK3 backflow prevention device	S15.2	6.11	Backflow prevention for filling	R15.30	6.50
Tap inlets above spillover			Transient pressures		
Backflow protection	G15.13	6.36	Occurrence and consequences	G5.4	3.14
Tap inlets discharging below spillover			Triggers, self closing		
Backflow protection	G15.14	6.38	Requirement for domestic hose	G15.17	6.41
Temperature			Tundish		
Hot water distribution	G18.2	8.9	Discharge from expansion relief valve	G19.4a	8.13
Hot water temperatures, combination boilers	G18.2	8.9	WC warning pipe discharge to	G25.7	9.8
Wholesome water, maximum for	G20.5	8.18	Type B upstand		
Temperature – operational			Definition	S15.1	6.10
Pipes to be capable of withstanding	G3.3	3.5	Types of distribution system		
Temperature at hot outlets			Methods of supplying	G8.2a	4.5
Health care premises	G18.6	8.10	Underground fittings		
Temperature control device			Dezincification resistant	G7.9	3.24
Provision for, in HW storage over 15lts	G17.1a	8.4	Exceptions to minimum depth of cover	R7.8	3.22
Temperature of cold water			Minimum depth for	G7.7	3.22
Maximum for distributed water	G9.1	4.10	Prohibition on use of adhesives	G7.10	3.24
Temperature relief valves			Protection from damage or frost	G7.8	3.22
Automatic closing expansion & temperature valves	G22.1	8.21	Unoccupied properties		
Discharge over tundish	G19.3	8.11	Protection against freezing	G4.3	3.6
Requirement for, with non-mechanical safety devices	G23.2	8.23	Unvented hot water systems		
Specification for discharge pipes from,	G19.3	8.11	Requirements for safety of	G17.1	8.4
Specification to BS6283(2)	G23.1	8.22			
Vented hot water system, solid fuel heated	G20.6	8.18			

# Index

	Clause	Section Number and Page		Clause	Section Number and Page
Unvented primary circuit			Washing machine		
Description	R17.1.2	8.6	Backflow protection	G15.16	6.41
Unwholesome water			Limitation on water consumption	R29.1	11.4
Colour-coded pipes to distinguish	G14.1	5.4	Waste outlets		
Urinal flush volume			Applications where plug not required	G28.1	10.6
With pressure flushing valves	G25.13	9.14	Water Byelaws in Scotland		
Urinal flushing			Text of		11
Requirement for flush time control	G25.10	9.10	Water closets		
Urinal flushing devices			Requirements for WC pans and flushing devices	R25.11	9.11
Specification for urinal flushing devices	G25.9	9.8	Water connection		
Urinal manual flushing valve			Ponds, fountains and pools	G31.2	12.6
Backflow protection for	G15.12	6.33	Water consumption		
Urinals			Domestic appliances	G29.1/3	11.4
Filling rates for automatic flushing of	G25.12	9.13	Water draw-off – kitchen sink		
Flushing devices for	R25.9	9.8	Location of drinking water point	G26.2	10.4
Use of Guide			Water fittings		
Notes on,		viii	Adequate for purpose	G3.1	3.4
Vent pipes			Capable of withstanding operational temperatures	G3.3	3.5
Discharge from primary not to wholesome water	G20.9	8.20	Underground, minimum depth for	G7.7	3.22
Discharge from secondary not to primary cistern	G20.10	8.20	Water Fittings and Materials Directory		
Discharge not to primary feed cistern	G20.10	8.20	Selection of fittings	G2.3	2.13
Discharge point, primary circuits	G20.1	8.13	Water Fittings Regulations		
Height of	G20.3	8.14	General Guidance		16
Minimum size to protect from freezing, secondary	G20.2	8.14	Summary		2
Vent size			Text		3–8
Primary hot water circuits	G20.1	8.13	Water for non-domestic applications		
Vented distribution pipes			Backflow protection	G15.18	6.41
For backflow protection of cistern fed systems	G15.6	6.27	Water for outside use		
Vented hot water storage			Backflow protection, hose pipes for house gardens	G15.20	6.42
Temperature relief	G20.6	8.18	Self-closing trigger, hose pipes for house garden and other applications	R15.17	6.41
Vented primary circuit			Water supplies for house garden use in existing premises	R15.21	6.43
No discharge in normal operation	R20.3	8.14	Water hammer		
Vented system			Cause and attenuation of	G5.4	3.14
Mechanical safety devices	G20.6	8.18	Effect on system operating pressure	G5.3	3.14
Verifiable backflow device			Water level		
Definition of	S15.1	6.10	In cisterns with alternative warning devices	G16.5	7.6
Verifiable double check valve			Water Regulations in England and Wales		3
EC backflow prevention device, description	S15.2	6.11	Water softeners		
Visual alarms			Description of types of	R11.3	1.7
Storage cisterns	G16.5	7.6	For domestic use, fluid category 2	Table G6.1b	6.2
Warning & overflow pipe					6.5
Cold water storage cistern, requirements	G16.13	7.11	Water supplies		
Warning devices			Code of practice for supply to pigs	G30.5	12.6
Requirement for overflow and warning pipe	G16.8	7.8	Water system design factors		
Storage cisterns	G16.5	7.6	Contaminated environment	G8.1	4.4
Common pipe, identifiable, conspicuous discharge	G16.12	7.11	Water systems		
Equally effective alternative devices,	G25.6	9.6	Flushing for cleaning of	G13.1	4.19
Flexible hose attached to, prohibition of	G16.8	7.8	Water tightness		
Required fall in installation	G16.8	7.8	Cold water storage cistern	G16.13	7.11
Requirement for	G16.8	7.8	Suitability of fittings	R4.1	3.6
Washbasin inlets			WC flushing		
Above spillover, backflow protection	G15.13	6.36	Requirement to clear pan contents	G25.1	9.4
Below spillover, backflow protection	G15.14	6.38	WC flushing cisterns		
Washbasin or trough			Requirement for marked water line	G25.4	9.5
Self-closing taps, plug not required	G28.1c	10.6			

	Clause	Section Number and Page
WC manual flushing valve		
Backflow prevention, pressure flushing valve	G15.12	6.33
WC warning pipe		
Discharge into WC pan	G25.8	9.8
Wet sprinkler systems		
Backflow protection	G15.27	6.48
Whole installation		
Hydraulic testing of systems	G12.1/3	4.17
Whole site backflow protection	G15.24 G15.26	6.45 6.47
Wholesome water		
Applications not requiring, Drinking water from storage cistern	G2.6 G27.2	2.14 10.4
Requirement for tap supplying drinking water	G27.1	10.4
Requirement of softened water for drinking	G7.3	10.5
Working pressure		
Pressure testing	G12.1	4.17
Written approval		
Commentary		16
Pumped showers	G6.2	3.16
Water supplier's, before installation starts	Byelaw 5 Reg. 5	13 5
Zone backflow protection	G15.24 G15.26	6.45 6.47
Zone protection		
Industrial and commercial applications	G15.18	6.41

## Abbreviations and Symbols

GL	Ground level	
WC	Water closet	
WB	Washbasin	
SL	Spill-over level	
WP	Warning/overflow pipe	
SV	Stopvalve	
SgV	Servicing valve	
CV	Appliance control valve or tap	
DT	Drain tap	
T	Tundish with air gap	
SCV	Single check valve	
DCV	Double check valve	
FC	Siphonic or non-siphonic flushing cistern	
PFC	Pressure flushing cistern	
FV	Pressure flushing valve	
PRV	Pressure reducing valve	
TRV	Temperature relief valve	
TPRV	Combined temperature and pressure relief valve	
EV	Expansion valve	
ExVI	Expansion vessel	
S	Strainer	
AVV	Anti-vacuum valve	
PIDC	Pipe interrupter with permanent atmospheric vent	
PIDB	Pipe interrupter with atmospheric vent and moving element	