

<b>Test Code Sheet Number</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>19</b>
-------------------------------	----------	----------	----------	----------	-----------

TEST CODE SHEET

---

**1. TYPE OF TEST(S)**

Closing pressure of the downstream check valve.

**2. WATER REGULATIONS REQUIREMENTS FOR FITTINGS**

Schedule 2

15-(1) .... every water system shall contain an adequate device or devices for preventing backflow of fluid from any appliance, fitting or process from occurring.

**3. BRITISH STANDARDS OR WATER SPECIFICATION, DEEMED TO SATISFY WATER REGULATIONS REQUIREMENTS**

3.1 Fittings with 'kitemarks' which are deemed to satisfy the requirements of regulations are listed in the directory.

**4. TEST PROCEDURE**

Note Unless otherwise stated the temperature of the test fluid shall be  $20 \pm 10^{\circ}\text{C}$ .

4.1 Tests applicable to the following:-

**NON-VERIFIABLE DISCONNECTOR CA**

DN6 to DN50.

Devices for the prevention of contamination by backflow.

---

(A) **NON -VERIFIABLE DISCONNECTOR CA** (Derived from prEN W1097 C25: 1999. Clause 9.5.2 )  
DN6 to DN50.

**TEST METHOD**

**APPARATUS** The following apparatus is required.

A supply of water to achieve the test pressures.

Sight glass, graduated in mm.

**PROCEDURE** The procedure shall be as follows:

- (1) Remove or foul the upstream check valve and ensure that the relief valve outlet is watertight.
- (2) Mount the device in the test system in its normal working position.
  - (a) Set up the device to be tested as shown in Figure 30A. The maximum inside diameter of the level tubes shall be 10 mm.
  - (b) Admit water to the device so that a height "h<sub>1</sub>" of the water column in tube 'C' is obtained.
  - (c) Isolate the device for 15 minutes ( $\pm 30$  seconds).
  - (d) Note the height difference  $\Delta H_1$ .
  - (e) Drain off a small amount of water downstream.
  - (f) Isolate the device for 15 minutes ( $\pm 30$  seconds).
  - (g) Note the height difference  $\Delta H_2$  (See Figure 30B).

<b>Test Code</b>					
<b>Sheet</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>19</b>
<b>Number</b>					

Issue No: 2  
Date of issue: June 2000

Sheet 2 of 2

5. **ACCEPTANCE CRITERIA**

The closing pressure of the check valve will be observed if  $\Delta H1$  and  $\Delta H2 > 100$  mm; or 50 mm of water if a WRAS approved check valve EB is incorporated.




Figure 30A




Figure 30B