

Ref. No.	Subject of relaxation	Schedule 2 Clause	Terms of the Relaxation	Conditions applying to the relaxation	Effective date
1	Shower (bidet) toilets for disabled users.	Schedule 2(15)(3): The device used to prevent backflow shall be appropriate to the highest applicable fluid category to which the fitting is subject downstream before the next such device.	Each Water Supplier to apply to the Secretary of State for a (non-site specific) relaxation. Subsequently, the Water Supplier can accept installations, subject to the conditions, without further notice to the Secretary of State. Water Suppliers to maintain a database of sites where relaxations have been utilised.	<ol style="list-style-type: none"> <li>1. The unit must be fed through a float-operated valve conforming with BS 1212 Parts 2 and 3.</li> <li>2. An appropriate warning pipe should be fitted to discharge in a conspicuous position.</li> <li>3. The unit must be removed when it is no longer required for the use of disabled people.</li> <li>4. The unit must be regularly serviced under a formal servicing contract, copies of which must be available on request to [water company] or through the water company to the Secretary of State, should he so request.</li> <li>5. Failure to comply with these conditions will invalidate the relaxation of the Regulations and may result in requirements for the [name of device] to be removed.</li> <li>6. The Secretary of State, through [water company], must be informed when the unit is removed.</li> </ol>	<p>England: from 9 Nov 1999</p> <p>Scottish Water: 2 Feb 2011.</p>