

Ref. No.	Subject of relaxation	Schedule 2 Clause	Terms of the Relaxation	Conditions applying to the relaxation	Effective date
3	Mikrofill device for backflow prevention	Schedule 15(5): A backflow prevention device is adequate for the purposes of paragraph (1) if it is in accordance with a specification approved by the regulator for the purposes of this Schedule.	To permit the Mikrofill backflow prevention device as an acceptable device for prevention of backpressure and back siphonage of fluids up to fluid category 4 in permanent installations for filling sealed primary heating circuits, with or without additives, in domestic and non-domestic premises.	That where a water supplier so requests, the manufacturer or supplier of Mikrofill will provide the water supplier with details of all the devices ordered for installation in that water supplier's area.	<p>England: 4 May 2001</p> <p>Wales: 10 May 2001</p> <p>Scottish Water Authorities: March 2002.</p> <p>Scottish Water: 2 Feb 2011</p>