

<b>Test Code Sheet Number</b>	<b>1</b>	<b>6</b>	<b>1</b>	<b>1</b>	<b>8</b>
---------------------------------------	----------	----------	----------	----------	----------

WBS TEST & ACCEPTANCE CRITERIA  
PD.

Issue No: 2  
Date of issue: September 1993

Sheet 1 of 1

TEST CODE SHEET

---

1. **TYPE OF TEST(S)**

Visual inspection - seal to be readily renewable.

2. **BYELAW REQUIREMENT FOR FITTINGS**

Byelaw 64

Every stop valve.....shall - (c) except in the case of a plug valve, be so designed or adapted that its seal can be readily renewed;.....

Byelaw 66

Every supply pipe in premises shall be fitted with a draining tap which.....(b) is so designed or adapted that its seal can be readily renewed.

3. **BRITISH STANDARDS OR WATER SPECIFICATION, DEEMED TO SATISFY BYELAW REQUIREMENTS**

(See Water Supply Byelaw Guide)

3.1 Fittings with 'kitemarks' which are deemed to satisfy the requirements of byelaws are listed in the directory.

4. **TEST PROCEDURE**

4.1 Tests applicable to the following:-

**TAPS**- draining

**VALVES** - stop

---

(A) **DRAINING TAPS AND STOPVALVES**

TEST METHOD

Dismantle the fitting as required and carry out a visual inspection of the method of renewing its seal.

5. **ACCEPTANCE CRITERIA**

The seal of the fitting shall be readily accessible for the purposes of renewal.