

Test Code Sheet Number	2	2	1	3	7
---------------------------------------	----------	----------	----------	----------	----------

TEST CODE SHEET

1. **TYPE OF TEST(S)**

Visual inspection.

2. **WATER REGULATIONS REQUIREMENTS FOR FITTINGS**

Schedule 2

15-(1) every water system shall contain an adequate device or devices for preventing backflow of fluid from any appliance, fitting or process from occurring.

3. **BRITISH STANDARDS OR WATER SPECIFICATION, DEEMED TO SATISFY WATER REGULATIONS REQUIREMENTS**

3.1 Fittings with 'kitemarks' which are deemed to satisfy the requirements of regulations are listed in the directory.

4. **TEST PROCEDURE**

4.1 Tests applicable to the following:-

CHECK VALVES

DN6 to DN250.

Devices for the prevention of contamination by backflow.

(A) **CHECK VALVES** (Derived from ASSE 1024 & 1015. Clause 3.7 & 3.6)
DN6 to DN250.

TEST METHOD

APPARATUS The following apparatus is required.

Visual examination with the naked eye.

PROCEDURE The procedure shall be as follows:-

Visually examine the movement of the first and second check valve through the full limit of their travel to ensure that it will not effect the operation of the other check valve.

5. **ACCEPTANCE CRITERIA**

If any movement of one check valve causes the other check valve to move off its sealing surface, it shall be cause for rejection.